

DCP300 Model Selection Guide with Price Data

Model Selection Guide
57-77-16-15 Issue 6

Honeywell Proprietary

Instructions

- Select the desired Key Number. The arrow to the right marks the selection available.
- Make one selection each from Table I thru VI, using the column below proper arrow.
- A dot (•) denotes unrestricted availability. A letter denotes restricted availability.

Key Number I II III IV V VI

_____ - _____ - _____ - _____ - _____ - _____ - _____

List Price equals the sum of all prices for all selections made.

KEY NUMBER	Description	Selection	Availability	
1	Channel Digital Controller/Programmer	P301	↓	
2	Channel Digital Controller/Programmer	P302		↓

TABLE I

Outputs	Channel 1	Channel 2 (P302 Only)			
	Relay (5 Amp)	Current	0D	•	•
Position Proportional	Current	2G	•	•	
Current (4 - 20 mA)	Current	5G	•	•	
Relay/Relay (Heat/Cool)	Current	3D	•	•	
Current/Current (Heat/Cool)	Current	5K	•	•	

TABLE II

Inputs				
One Input Channel		0	•	
Two Input Channels		1		•
Temperature/Relative Humidity Calculation		2		•

TABLE III

Power				
Universal Power - 90 to 264 VAC, 50/60 Hz		ES	•	•

TABLE IV

Option 1				
None		00	•	•
1 Auxiliary Output		01	•	a
2 Auxiliary Outputs		02	a	

TABLE V

Option 2				
4 Digital Inputs + 3 Events - (Standard features)		0	•	•
12 Digital Inputs + 3 Events + 5 Time Events		1	•	•

TABLE VI

None				
		00	•	•

RESTRICTIONS

Restriction Letter	Not Available With		Available Only With	
	Table	Selection	Table	Selection
a	I	2G, 3D, 5K	I	0D, 5G